

**NOTES:**


1. SEE STRUCTURAL AND ARCHITECTURAL DRAWINGS AND SPECIFICATIONS FOR REQUIRED HORIZONTAL JOINT REINFORCING, BOND BEAMS AND ADDITIONAL VERTICAL REINFORCEMENT.
2. PROVIDE DOWELS WITH HOOKS INTO FOUNDATION AT ALL VERTICAL REINFORCEMENT. DOWELS TO MATCH VERTICALS IN SIZE AND SPACING.
3. ALL CELLS CONTAINING VERTICAL REINFORCEMENT SHALL BE SOLID GROUTED FULL HEIGHT.

## 8" MASONRY WALL REINFORCING

SCALE: 3/4" = 1'-0"

**Disclaimer note**

This detail must not be used without the final and complete review and evaluation by the design professional. The design professional assumes total and final responsibility for this detail as explained in Responsibilities and Legal Notices in the axiomcpi.com website. Please remove the review text boxes and this disclaimer note after review.



SSD08.0-04	■
V1.1	